Current Efficiency Standards

D.O.E. 3 Phase Commercial Products

Air-Cooled Products	Туре	Current Standard ASHREA 90.1 - 2013	
		AC	Heating
≤ 65,000 Btu/h 3 Phase	Split System Air Conditioners	13 SEER	
	Split System Heat Pumps	14 SEER	8.2 HSPF
	Package Air Conditioning	14 SEER	
	Package Heat Pumps	14 SEER	8.0 HSPF
	Package Gas/Electric	14 SEER	81% AFUE
> 65,000 - <135,000 Btu/h	Air Conditioners w/ Electric Heat or No Heat	12.9 ieer	
	Air Conditioners w/ Any Other Heat Type		
	Heat Pumps w/ Electric Heat or No Heat		
	Heat Pumps w/ Any Other Heat Type		
> 135,000 - 240,000 Btu/h	Air Conditioners w/ Electric Heat or No Heat	12.4 ieer	
	Air Conditioners w/ Any Other Heat Type		
	Heat Pumps w/ Electric Heat or No Heat		
	Heat Pumps w/ Any Other Heat Type		
> 240,000 - <760,000 Btu/h	Air Conditioners w/ Electric Heat or No Heat	11.6 ieer	
	Air Conditioners w/ Any Other Heat Type		
	Heat Pumps w/ Electric Heat or No Heat		
	Heat Pumps w/ Any Other Heat Type		